

PRE-BID CONFERENCE ATTENDANCE ROSTER

Solicitation Number: #81010-21-01
Meeting Date: June 7, 2021
Mandatory: YES

Location:
Dooms Crossing Road
Time: 2:00 p.m.

Other Notes:
Doug Wolfe, Jeff VanFossen - Augusta County
Louise Finger, DWR
Robert VonBernuth, adjacent property owner

Representative Name	Company		
Larry Mohn	Shenandoah Streamworks, LLC		
	Atkins Excavating, Inc		
Email Address	Address	City/State/Zip	Telephone Number
shenstreamworks@aol.com	139 Slate Hill Rd	Weyers Cave, VA 24486	540.908.9769

Representative Name	Company		
Daniel Runion	Burleigh Construction		
Email Address	Address	City/State/Zip	Telephone Number
drunion@burleighconstruction.com	7610 Village Hwy	Concord, VA 24538	434.993.2214

Representative Name	Company		
Anthony Jordan	Safeco Environmental, Inc		
Email Address	Address	City/State/Zip	Telephone Number
bjordan@safecoservices.com	3082 South Highway 88	Dilliner, PA 15327	304.906.8602

Representative Name	Company		
John Douthat	Allegheny Construction Inc		
Email Address	Address	City/State/Zip	Telephone Number
john@alleghenyconstruction.net	2830 Nicholas Ave	Roanoke, VA 24012	540.345.0817

Representative Name	Company	Address	City/State/Zip	Telephone Number
Jim Howdyshell	Howdyshell Excavating, Inc	682 North River Rd	Mt Solon, VA 22843	540.350.2471
Email Address jhowdy@ntelos.net				

Representative Name	Company	Address	City/State/Zip	Telephone Number
Raul Vargas	RES	5367 Telephone Rd	Warrenton, VA 20187	703.855.7112
Email Address rvargas@res.us				
region2estimating@res.us				

Representative Name	Company	Address	City/State/Zip	Telephone Number
Justin Michael	The Frazier Quarry	75 Waterman Drive	Harrisonburg, VA 22802	540.478.0004
Email Address justin.michael@frazierquarry.com				

Representative Name	Company	Address	City/State/Zip	Telephone Number
Kory Strader	KBS	5616 Coble Church Rd	Julian, NC 27283	336.362.0289
Email Address kory@kbsearthworks.com				

Questions arising during the pre-bid meeting

1. Is the 45 days for the Rockfish entrance inside of the 90 days for the Dooms Crossing Rd entrance, or on top of?

Answer: Inside, Rockfish to be completed within 45 days of NTP, Dooms Crossing Rd to be completed within 90 days of NTP

2. VDOT entrance permit?

Answer: We have clarified with VDOT that they will accept a letter from the county in lieu of a bond, so no separate bond is required.

3. Soil lifts, is each layer a lift?

Answer: Yes, we will pay on the total LF of soil lifts. Projected length is 1600 LF, assuming 2-3 lifts over the 600 LF of channel

4. Northern termination of the streambank stabilization?

Answer: The northern termination of the streambank stabilization will be field determined and will tie in to existing.

5. There was discussion around the mention of Point Bar material (noted on Sheet 2/13 in the E&SC Narrative)

Answer: Accumulated sediment behind the dam that is being removed will not be disturbed. Other areas of point bar material downstream of the dam on county property MAY be utilized at the discretion of the DWR biologist. Excavation, transportation and placement of this material would then be paid under the hourly rates for items 31-35.

6. May we use the riverbed as a haul road.

Answer: No, material from the dam site is hauled out the Dooms Crossing Rd entrance and across the Rockfish Rd access roadway to the bank stabilization site.

7. The Rt 865 (Rockfish Rd) access, does it get retopsoiled?

Answer: No, this access is intended to remain for use by the property owner as a grassed farm lane

8. Mercury contamination?

Answer: This job is in the area downstream of the former DuPont plant in Waynesboro and there is residual Mercury in the sediments on the job site. No soil material is to leave the jobsite, but material may be moved around within the work limits

9. Marking of trees to remain?

Answer: Trees to remain will be marked after the alignment is staked by the contractor. Intent is a park like setting, therefore, tree removal will be limited to that necessary to install the access